

**Response of
Wisconsin Power and Light Company and
Wisconsin Electric Power Company
to
The Public Service Commission of Wisconsin
Data Request No. 6.08**

Docket Number: 05-CE-137
Date of Request: August 27, 2009
Information Requested By: Jim Lepinski
Date Responded: September 14, 2009
Author: Jeff Knier
Author's Title: Manager Engineering Projects
Author's Telephone No.: (608) 458-4866
Witness: (If other than Author)

Data Request No. 6.08:

Provide the expected duration of the tie-in outage.

Response:

The planned tie-in outage duration for the SCR is 6 weeks.